



Park Hill School District

Building Successful Futures • Each Student • Every Day

ADDENDUM No. 3

Park Hill School District

2019 Roofing Projects

February 1, 2019

You are instructed to read and note the following described changes, corrections, clarifications, omissions, deletions, additions, approvals and statements pertinent to the Construction Documents.

Addendum No. 3 is a part of the Contract Bid and Construction Documents and shall govern in the performance of the Work.

I. Scope of Work Additions and Changes

A. Plaza Middle School – Roof O

1. Adhere ½” high-density primed wood fiber insulation over nailed base sheet prior to installing 4-ply roof membrane.
 - a. Adhere with hot Type IV asphalt.

ACKNOWLEDGEMENT: Each Bidder shall acknowledge receipt of Addendum No. 3 on the Bid Form.

END OF ADDENDUM NO. 3