



## ADDENDUM 1

<b>RFB NUMBER:</b>	TE1102 – Audio Visual Systems Renovations V
<b>ADDENDUM NUMBER:</b>	1
<b>ADDENDUM ISSUED:</b>	02/27/2020

### I. CHANGES

The original Request for Bid No. TE1102: Audio Visual Systems Renovations remains in effect except as revised by the following changes, which shall take precedence over anything to the contrary in the specifications.

### II. QUESTIONS & ANSWERS

The following questions are as they were presented to Park Hill School District. The answers to said questions have been answered as completely and accurately as possible.

**Q1: The project specification does not outline the expectation for power (line voltage) to be included in the project. However, it was discussed at the pre-bid meeting that this was to be included. Please confirm if the AV contractor is responsible for including power work (for racks, projector screens and projectors) in our proposal. If this is required, we would appreciate some guidance as to the specifications of such work.**

**A: Power needs to run to the nearest available panel with appropriate size and quantity of wires. Open ceiling requires NEC approved conduit specifications. Above ceiling can be Metal Clad Flex (MCF). Pathways to be determined and approved onsite.**

**Q2: Does a custom rackshelf for the HD400 [Intel NUC] need to be provided? How does the district expect this to be installed the rack?**

**A: Please refer to Drawing AVD2 with elevation specifications. Each rack calls for a Middle Atlantic UFA-8-F1 shelf. HD400 to be secured with Velcro or zip ties.**

**Q3: The SE gym equipment rack is being installed in a telecommunications closet. Since this is a secured space, can the plexiglass front door be omitted?**

**A: No, due to limited space there is a high risk of impact from equipment and personnel.**

**Q4: What is the scope of the surface mount infrastructure in the gymnasium area?**

**A: A separate pathway for each cluster of surface mount controls and inputs is required.**



### III. ACKNOWLEDGEMENT

Each bidder shall acknowledge receipt of this Addendum No. 1 of Bid No. *TE1102: Audio Visual Systems Renovations V* by his/her signature affixed hereto and shall attach this Addendum to the original proposal submitted. Failure to sign and submit this addendum may render your proposal Non-Responsive.

Certification by Bidder:

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

Title: \_\_\_\_\_ Company: \_\_\_\_\_